





When you first power up the device, the following page is displayed.



For preliminary setup, press the SET button for at least 

1

Enter the CT value

The CT value is the ratio of the primary divided by the CT secondary

Example:
CT 100/5A => CT ratio = 20



Press



Modify the value with



Confirm with



Appuyer sur



2

Enter the FSA value

The FSA value is the CT secondary value

Example:
CT 100/1A => FSA = 1



Press



Modify the value with




Confirm with



3

Save and exit

Press for 



Confirm with

